



PSD15/3/FP/9/ 728

Protection and Safety Directorate
Dated: 12th February 2017

M/S. OMNIA VENTURES
P. O. BOX NO. 32155,
Seef District.
Kingdom of Bahrain.

Dear Sir,

PRODUCT APPROVAL: ACRYLIC PANELS
(DECORATIVE WALL PANELS)

Thank you for your submittal No. OMN-2017-0001 dated 26th January 2017, enclosing product catalogue, samples and international test report for the (LP01 and Tri-Axial from Acrylic One) Acrylic panels manufactured by **M/S SUBER SYSTEM, Turkey.**

As this product is tested according to European standard by the EFECTIS Nederland BV for the classification of reaction to fire performance (B – S1,do) vide report No. 2006-CVB-R0565 dated 5th November 2015

Therefore, the General Directorate of Civil Defence have no objections to the supply, installation of the subjected decorative wall panels directly to finished plaster walls, within the Kingdom of Bahrain.

This certificate is valid up to 12th February 2018.

Yours faithfully,



For Colonel
Director Protection & Safety Directorate
General Directorate of Civil Defence
Lieut. Colonel Sa'ad Hassan Al-Naimi

/sna.