



PSD15/3/FP/9/4357

Dated: 26th November 2015

M/S. OMNIA VENTURES
P. O. BOX NO. 32155,
Seef District.
Kingdom of Bahrain.

Dear Sir,

PRODUCT APPROVAL: ACRYLIC PANELS
(DECORATIVE WALL PANELS)

Thank you for your submittal No. OMN-2015-0003 dated 9th November 2015, enclosing product catalogue, samples and international test report for the (LP01 and Tri-Axial from Acrylic One) Acrylic panels manufactured by **M/S SUBER SYSTEM, Turkey.**

As this product is tested according to European standard by the EFECTIS Nederland BV for the classification of reaction to fire performance (B – S1,do) vide report No. 2006-CVB-R0565 dated September, 2006.

Therefore, the General Directorate of Civil Defence have no objections to the supply, installation of the subjected decorative wall panels directly to finished plaster walls, within the Kingdom of Bahrain.

Yours faithfully,

For Colonel
Director Protection and Safety Directorate
General Directorate of Civil Defence
Lieut. Colonel Sa'ad Hassan Al-Naimi



PSD-PSB-D/02/V01

/sna.